

PUBLIC PRIVATE SCHOOLSTATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC PRIVATE SCHOOL
INSPECTION REPORT

Geocoded 25.805710/-80.226798

PURPOSE:
 ROUTINE
 CONSTRUCT.
 COMPLAINT
 QA SURVEY
 OTHER

REINSPECTION
 CHANGE OF OWNER
 CONSULTATION
 EPIDEMIOLOGY
 PREOPENING

TYPE: **Public School**

CENSUS	FEMALES	MALES
722	361	361



NAME Maya Angelou Elementary

ADDRESS 1850 NW 32nd Street **CITY** Miami

OWNER M-DCSB **ZIP** 33142

PERSON IN CHARGE Adrena Y. Williams **PHONE** (305) 636-3400

E-MAIL mdgarcia@dadeschools.net

RESULTS:

Satisfactory
 Incomplete
 Unsatisfactory
OUT OF BUSINESS

Correct Violations by

Next Inspection
 8:00 AM on

BEGIN TIME	END TIME	DATE ASSESSED	POSITION #	EXISTING FACILITIES - PERMIT NUMBER
12:30	13:45	10/31/2013	32763	13-51-08382

RE-INSPECTION DATE

As per section 120.695 of the Florida Statutes (FS), this form will serve as a "Notice of Non-Compliance: for any violations noted. Items marked below violate the requirements of Chapters 64E-13 and 64E-11 of the Florida Administrative Code (FAC) and must be corrected within the time period indicated in the "Results" section above. Continued operation of this facility without making these corrections is a violation of Chapter 64E-13 and 64E-11, FAC, and Chapter 381, FS. Failure to correct violations may result in an administrative fine or other legal action being initiated or continued.

SCHOOL SANITATION

1. School Site
 2. Playground Equipment
 3. Athletic Equipment

BUILDINGS

4. Construction
 5. Maintenance & Repair
 6. Lighting/Foot-Candles
 7. Heating, Ventilation, A/C

8. Natural Ventilation

9. Mechanical Ventilation

SANITARY FACILITIES

10. Provided/Accessible
 11. Cleanliness & Repair
 12. Toilet Facilities
 13. Separation of Sexes
 14. Fixture Ratio

15. Handwash Facilities

16. Showers/Fixtures

17. Shower Water Temp.

WATER SUPPLY

18. Installed/Operated/
Maintained
 19. Drinking Fountains
 20. Approved Source

LIQUID/SOLID WASTE

21. Sewage Disposal
 22. Solid Waste

VECTOR/VERMIN CONTROL

23. Infestation/Control
 24. Brush/Trash
 25. Water Collection/Drainage

SAFETY

26. First Aid Kit

FOOD

27. Food Insp. Rpt.

OTHER

28.
 29.

COMMENTS AND INSTRUCTIONS

Violation #2 Repair playground, observed loose handles and damaged equipment. Playground is not being used.
Code Reference FAC: Playground Equipment 64E-13.004(2)(a)(c). Playgrounds shall be constructed and maintained to permit maximum utilization of sites with elimination of sanitary and health hazards including mudholes, fragments of glass, stone and similar obstructions. Fixed playground equipment shall be anchored with substantial foundations so maximum safety is obtained. Cushioning materials such as mats, wood chips, or sand shall be used under climbing equipment, slides, and swings.

Violation #6 Replace burnt out light in restroom in room 72.

Code Reference FAC: Lighting/Foot-Candles 64E-13.004(4)(a-d). Illumination in all instructional spaces shall be designed to provide a minimum of forty (40) foot-candles glare free at normal task level. Fixtures shall be so located that there will be uniform (within ten (10) foot-candles) illumination suitable for the activities conducted therein. All required illumination shall be designed so that the failure of any single unit, such as the burning out of an electric bulb will not leave any occupied area or means of egress in darkness. Illumination of chalkboards and other visual aids shall be designed to eliminate glare and shadows.

Provide sanitary napkin disposal/lined trash cans in each stall in girls gang restroom.

Violation #11 Replace or secure toilet seat in girls gang restroom. Clean cent in boys gang restroom, dusty.

Code Reference FAC: Cleanliness & Repair 64E-13.004(6)(a). Walls to a height of at least 4' feet toilet partitions and floor of all toilet rooms shall be finished with impervious materials. All plumbing fixtures shall conform to the provisions of the local plumbing code. All group toilet rooms shall be provided with at least one (1) floor drain and (1) hose bib. The floor shall be sloped to the drain. Deodorizers shall not be used in toilet rooms.

Violation #13 Provide separate toilet facilities for girls and boys grade 4

****Continued On Page 2****

INSPECTION CONDUCTED BY: Christine Oliver PHONE: (305) 623-3500 ex. 23422

INSPECTION COND SIGNATURE: *Christine Oliver* PHONE2: (305) 623-3500 ex. 23422

COPY OF REPORT RECEIVED BY: *Joe B. Garcia* DATE: 10/31/2013

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY PUBLIC HEALTH UNIT
Public/Private School



Name: Maya Angelou Elementary

Date: 10/31/2013

Identification No: 13-51-08382

Comments and Instructions (Continued from Page 1):

and above, observed 94-2 and 96-1 and 79-1 being used for boys and girls.

Code Reference FAC: Separation of Sexes **64E-13.004(6)(a)(1.)**. Preschool grades through grade three shall be provided with toilet and handwashing facilities located within or adjoining classrooms and considered adequate without urinals. Common toilet facilities for both sexes shall not be allowed above the third grade.

Violation #15 Provide paper towels and soap in girls gang restroom. Seure sink in classroom 70, 33, 79, and library; loose.

Code Reference FAC: Handwash Facilities **64E-13.004(6)(b)**. Handwashing facilities shall be located within or adjoining each toilet room. Soap dispensers shall be provided at all wash basins and liquid or powdered soap shall be used. Individual towels, preferably paper shall be used. Use of common or public towels is prohibited. Hot-air hand drying devices

Violation #19 Repair water fountain near room 068 and in room 28, very low pressure.

Code Reference FAC: Drinking Fountains **64E-13.004(7)(b)**. Drinking fountains of an approved, sanitary slant jet type shall be provided in the ratio specified in the local building code or Chapter **64E-10**, F.A.C. In no case shall fountains be located in any toilet room.

Copy of Report
Received By: *Yuse D. Davis*

Inspector Christine Oliver